

Building Product Information Sheet

Product name:

CleanVent Air & Dirt Separator

Product line (the product line from which the product is customised):

Filtration

Product description and its intended use (measurements, materials, usage):

CleanVent combines the removal of air and dirt through a single unit. Available from flange sizes 50mm to 600mm. Installed it will eliminate all dirt particles down to 5 microns. The advantage of stainless steel is its smooth surface allows 99% of dirt, sludge & magnetite to be flushed out rather than sticking to the inside of the unit and recycling back into your system as it does with mild steel units.

Not for use with potable water.

Product identifier (if applicable):

FPADS65

Please of manufacturer: Aotearoa New Zealand Overseas

Legal and trading name of the manufacturer(s):

Fabricated Products UK Ltd

Legal and trading name of the manufacturer(s):

Central Heating New Zealand Ltd

Address for service:

STREET NAME 52 Pilkington Way

SUBURB Wigram

CITY, COUNTRY Christchurch, New Zealand

POSTCODE 8042

Website:

<https://www.centralheating.co.nz/>

Email Address:

info@centralheating.co.nz

Phone No. (if applicable):

03 357 1233

NZBN (if applicable):

9429036621231

Relevant Building Code clauses:

Clause B2 DURABILITY:

Performance B2.3.1 (b)

Clause F2 HAZARDOUS BUILDING MATERIALS:

Performance F2.3.1.

Clause G10 PIPED SERVICES:

Performance G10.3.1 (a).

Statement on how the building product is expected to contribute to compliance:

Clause B2 DURABILITY:

Performance B2.3.1 (b) 15 years. Stainless Steel components are moderately easy to access and replace if installed in accordance with the instructions and product requirements.

Clause F2 HAZARDOUS BUILDING MATERIALS:

Performance F2.3.1. Stainless Steel components meet this requirement and do not present a health hazard to people.

Clause G10 PIPED SERVICES:

Performance G10.3.1 (a). Stainless Steel components are intended for a non-potable piping system, which contributes to meeting this requirement when used in heating systems.

- *options for compliance set out in section 19 of the Act (regulations, acceptable solution, verification method)*
- *standard or technical document that describes the performance of the building product or the relevant specifications to which the building product was manufactured.*
- *physical properties of the building product*
- *how the building product is intended to be used.*

Limitations on the use of the building product:

Please refer to the CleanVent Air & Dirt Separator [technical information](#) provided on the Central Heating NZ website.

The hot water heating system must not be connected to the potable water supply system.

Design requirements that would support the use of the building product:

The heating system design, including the layout of the pipe, must be carried out by a suitably qualified designer.

Please refer to the filter technical information provided on the Central Heating NZ website.

Design must consider the requirement of building code clause H1 for pipework and heating design.

Installation requirements:

Please refer to the CleanVent Air & Dirt Separator [technical information](#) and installation instructions provided on the Central Heating NZ website.

Units must be installed at the hottest part of the system (before the pumps). In a heating system this is the main flow from the boilers.

In a chilled water system, the unit must be located in the return dose to the chiller.

The system installation must be carried out by a licensed and qualified tradesperson, in accordance with the design supplied by the suitably qualified designer.

A detailed as-built plan and site photos shall be provided upon the conclusion of installation showing location of all associated pipework and the filter location on a heating schematic.

Maintenance requirements:

The air and dirt separator requires periodical maintenance, to remove the deposited impurities and air from the system.

Is the building product/building product line subject to warning or ban under section 26:

Yes No

If yes, description of the warning or ban under section 26:

Date:

3 0 0 8 2 3